

IN AREAS WITH G.C.W.S.D. SEWER, METERS SHOULD BE SET AT OPPOSITE CORNERS FROM SEWER SERVICE LOCATIONS

BY INDIVIDUAL PROPERTY OWNER
BY CONTRACTOR

PROPERTY LINE

R/W

EXTEND 2' BEYOND E.O.P. BOTH ENDS

1-1/4" PVC 160 P.S.I. CASING

VARIES - SEE PLANS

ROADWAY WHERE APPLICABLE

WATER MAIN

PLAN

GEORGETOWN COUNTY
WATER & SEWER DISTRICT

RESIDENTIAL WATER METER
DETAIL - 3/4"

DATE	SCALE	N.O.
4-25-01	N.T.S.	10 - W
DRAWN	CHECKED	
C.L.E.	G.L.B.	

NOTE:

ALL FITTINGS TO BE I.P.S. FITTINGS

7" PLASTIC TURF BOX
J & D PRODUCT LINE
JD-7000 OR APPROVED
EQUAL

3/4" BRASS GATE VALVE
(H606 HAMMOND OR
APPROVED EQUAL)

SET BOX TO FINAL GRADE

5/8" X 3/4" X 7" METER YOKEBOX
MUELLER H1453D OR APPROVED
EQUAL (KIT INCLUDES BOX AS-
SEMBLY, INVERTED KEY VALVE,
EXPANSION CONNECTION, OUTLET
PIECE, & 'INSTA-TITE' COUPLING)

5/8" X 3/4" METER
BUTLER BRASS OR
APPROVED EQUAL

SILVERLINE I.P.S. BLUE
STRIPE TUBING (3/4" FOR
PROPERTY SIDE SHORT
SERVICE & 1" FOR ROAD
BORE LONG SERVICE)


3/4" BRASS DUAL CHECK
VALVE (WILKENS 34MX34
UF700 OR APPROVED EQUAL)

1-1/4" PVC 160
P.S.I. CASING FOR
ROAD BORES (WHERE
APPLICABLE)

3/4" MUELLER BRASS
'INSTA-TITE' I.P.S.
CORPORATION WITH
COMPRESSION NUT
OR APPROVED EQUAL
(CORPORATION KEY
FACING UPWARDS)

VINYL COATED SADDLE
WITH STAINLESS STEEL
WIDE STRAPPING &
CORPORATION THREADS
(ROMAC OR APPROVED
EQUAL)

3/4" BRASS NIPPLE
(3" LONG TYPICAL)



SECTION