

IN AREAS WITH G.C.W.S.D. SEWER, METERS SHOULD BE SET AT OPPOSITE CORNERS FROM SEWER SERVICE LOCATIONS


BY INDIVIDUAL PROPERTY OWNER
BY CONTRACTOR

PROPERTY LINE

R/W

VARIES - SEE PLANS

PLAN



GEORGETOWN COUNTY
WATER & SEWER DISTRICT

2" RESIDENTIAL WATER METER
TAP DETAIL WITH SHORT SERVICE
FROM WATER MAIN

DATE	SCALE	NO.
12-8-02	N.T.S.	16 - W
DRAWN	CHECKED	
	C.L.E.	

2" BRASS STRAIGHT DUAL CHECK VALVE (FORD HFS31-777 OR APPROVED EQUAL)

2" METER (SENSUS SR MODEL OR APPROVED EQUAL)

METER YOKEBOX (FORD "PROTECTOR" BOX OR APPROVED EQUAL) SET TO FINISHED GRADE

2" BRASS INLET KEY BALL VALVE MALE I.P.S. THREAD (FORD BF83-777W OR APPROVED EQUAL)

CAST IRON VALVE BOX WITH LID 24"-36" SCREW TYPE ADJUSTABLE NOTE: ALL VALVE BOX RISERS TO BE DUCTILE IRON

2" BRASS GRIP JOINT COUPLING (C.T.S.) WITH MALE I.P.S. THREADED

7" PLASTIC TURF BOX

2" BRASS GATE VALVE

2" X 6" BRASS NIPPLE THREADED W/ (2) 2" BRASS LOCKNUTS

2" BRASS FEMALE THREADED 45° BEND

2" MALE THREADED ADAPTER (BRASS)

2" C.T.S. POLY TUBING SILVERLINE BLUE STRIPE

FOR TAPS CLOSE TO THE MAIN, USE (2) 2" BRASS 90° BENDS INSTEAD OF (1) 45° BEND AS NEEDED

SECTION

2" SQUARE NUT GATE VALVE (MUELLER A-2360 W/THREADED ENDS OR APPROVED EQUAL)

VINYL COATED SADDLE WITH STAINLESS STEEL WIDE STRAPPING & CORPORATION THREADS (ROMAC OR APPROVED EQUAL)

