



NOTE: IF LESS THAN 18" CLEARANCE, CENTER 18 L.F. OF D.I.P. AT CROSSING FOR BOTH UTILITY LINES

<b>GEORGETOWN COUNTY WATER &amp; SEWER DISTRICT</b>		
<b>WASTEWATER LINE CROSSING BELOW STORMWATER LINE - SECTION</b>		
DATE	SCALE	NO.
DRAWN	CHECKED	